

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
526/19, Shivaji Nagar, Opp. S.D Public School (Khandsa Road),
Gurugram (e-mail: xenceiggn@gmail.com).**

To

M/s Burman Estate Pvt. Ltd.
Village- Shikhohpur, Sector-82A,
Town Square, Manesar, Gurugram.

Application No. 1781-3388 Dated: 30.1.23

Memo No: H.T.I/ 1750 Dated: 6.2.23

Registration No. 1200003511 Dated: 2/1/23

Subject: Inspection of installation comprising of 2x1010 KVA, 1x750 KVA
DG Sets Installed at M/s Burman Estate Pvt. Ltd. Manesar.

The subject cited installation was inspected by this department on 06/02/2023 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Approval for energisation of the same is hereby accorded.

However, it is advised that:-

1. Earth pits be maintained Properly.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end and the electrical installation be maintain and operated in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are further advised to install the smart meter to read the energy generated and send the monthly statement of the units generated from your DG Sets to this department.

Executive Engineer
Executive Engineer
Electrical Inspectorate, Haryana,
526/19, Shivaji Nagar, Opp. S.D Public School, Gurugram-1

CC: The Chief Electrical Inspector to Govt., of Haryana, Chandigarh for information with reference to discussion and directions on telephone please.