

Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
526/19, Shivaji Nagar, Opp. S.D Public School (Khandsa Road),
Gurugram (e-mail: xeneei@gn@gmail.com).

To

M/s Burman Estate Pvt. Ltd.,
Sector-82A, Manesar, Gurugram.

Application No. 3326-4353

Dated: 2/4/2022

Memo No: H.T.I./ 6839


Dated: 5/4/2022

**Subject: Inspection of HT installation comprising of 1x1600 KVA and 1X1000 KVA
33/0.433KV T/Fs at Burman Estate Pvt. Ltd.**

The subject cited installation was inspected by this department on 02/04/2022 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Approval for energisation of the subject cited installations is hereby accorded.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

Your next inspection shall fall due in the month of April every year. You are therefore requested to deposit inspection fee as per schedule under the Head of A/c "0043- Taxes and Duties on Electricity Fees payable under I.E Rules, 1956" and send the original receipted treasury challan to this office one month before the due date.


Executive Engineer
Electrical Inspectorate, Haryana,
Shivaji Nagar,
Gurugram-I

CC: The Chief Electrical Inspector to Govt. of Haryana, Chandigarh for information please

CC: The SDO OP S/Divn., DHBN, Manesar for information and necessary action.